

The goal of the Fire Safety Inspection Program is to assist you in making your business a safe place for your customers and employees. We also want to work with you to ensure that if a fire were to occur, damage is limited as much as possible and our firefighters can operate in a safe and efficient manner.

Practicing fire prevention and addressing any possible hazards in your business is a great investment!

A Fire Prevention Specialist from Wauseon will be stopping in to inspect your business in the near future. If you have any questions about this checklist or the inspection process, please contact the Fire Department.

We Care About YOU and YOUR BUSINESS!

Wauseon Fire Department
230 Clinton St.
Wauseon, OH 43567

Recipient
Street Address
City, ST ZIP Code



Wauseonfire.com
firechief@cityofwauseon.com

(419) 335-7831

Wauseon Fire Department
Preparing Your Fire Safety Inspection



FIRE INSPECTION CHECKLIST

We have compiled a list of the most common hazards to assist you in preparing your business for a fire safety inspection. Please feel free to discuss any questions or concerns you may have with your inspector.

— Do you have at least a thirty-six inch wide path to all of your exit doors?

— Do your exit doors open freely, with little effort, and are they unlocked?

— If equipped, are all fire doors able to close freely, and free of hold open devices?

— If equipped, are all exit and emergency lights operating, including backup power?

— Is storage contained so that nothing capable of burning is within two feet ceiling?

— Do you have at least thirty-six inches clear space around your furnace, water heater, and other heat-producing appliances?

— Do you keep the area underneath exposed interior stairwells free of storage?

— Are your walls and ceiling free of holes or missing acoustical tiles?

— Do you have all compressed gas cylinders secured or chained so they can't fall over?

— Are flammable liquids identified and stored in their original containers?

— Are utility shutoffs, fire alarm panels, and sprinkler controls easily accessible to firefighters in the case of an emergency?

— Are utility shutoffs, fire alarm panels and sprinkler controls clearly labeled?

— Is your maximum occupancy posted?

Electrical Hazards

— Is your business free of electrical overload, extension cords, and multi-plug adapters?

— Are all electric outlets and switch contacts covered with a safety plate?

— Is your business free of any electric boxes, exposed wiring, or open spaces in your fuse/breaker panel?

— Do you have at least thirty-six inch clearance around any fuse / breaker panel?

— Is your fuse / breaker panel clearly labeled so power can be disconnected quickly in the event of an emergency?

Exterior Hazards

— Are you storing anything that could burn close to your building or under overhangs?

— If your business has a designated fire lane, are the signs and / or paint markings in good condition?

— Is your address clearly visible from the street with at least four-inch contrasting numbers?

— Is there at least three feet of clear space around any fire hydrants on the property?

— Do you have a fire extinguisher installed so that an individual would not have to travel more than seventy-five feet to access one?

— Are all fire extinguishers within clear view and easily accessible?

— Have all fire extinguishers been inspected and tagged?

Fire Sprinkler Systems

Some buildings require a fire sprinkler system because of the size of the building or the type of business operation. If you have a sprinkler system installed, be sure to check the following:

— Has the fire sprinkler system been inspected and tagged by a qualified contractor within the past year?

— Is there at least three feet of clear space around sprinkler connection valves?

— Are spare sprinkler heads and an appropriate wrench installed in a cabinet near the sprinkler riser?

— Are sprinkler control valves chained open or maintained by a fire alarm system?

— Is the fire department connection on the outside of the building free of obstruction and are caps in place?

Fire Alarm Systems

Some buildings require a fire alarm system because of the number of occupants or the type of business operation. If you have a fire alarm system installed, be sure to check the following:

— Does the fire alarm system show "Trouble" or "Alarm" on the keypad or alarm panel? If so, contact a qualified alarm contractor to restore your system.

— Please ask your Fire Safety Inspector about our **KNOX BOX** program to prevent damage to your building in the event of a false alarm.